

SECTION 15936
GRILLES, REGISTERS, DIFFUSERS

PART 1 GENERAL

1.1 RELATED DOCUMENTS

- A. The other Contract Documents complement the requirements of this section. The General Requirements apply to the work of this section.

1.2 SCOPE

- A. Provide materials, devices, labor and supervision necessary for the installation of grilles, registers and diffusers.
- B. Provide grilles, registers and diffusers as per schedule.

1.3 QUALIFICATIONS

- A. Air distribution products by Price, Anemostat, Nailor, Titus or approved equal.
- B. Louvers shall be Ruskin, Airline, Cesco, Nailor or approved equal
- C. Design, specification and schedule based on Titus for diffusers and Ruskin for louvers.

PART 2 PRODUCTS

2.1 CEILING DIFFUSERS

- A. Provide ceiling diffusers of type and style with volume control dampers and accessories as scheduled.

2.2 CEILING RETURN AND EXHAUST REGISTERS

- A. Provide ceiling return and exhaust registers, match ceiling diffusers with opposed blade volume control as scheduled.

2.3 LOUVERS

- A. Louvers shall be of a minimum of 0.125" thick extruded aluminum frame and blades, 6" deep; AMCA certified (Standard 500) aluminum birdscreen and anodized finish, Ruskin Model 6375.

PART 3 EXECUTION

3.1 INSTALLATION

- A. In grid panel type ceilings, acoustical, etc., grilles, registers and diffusers shall be located in the center of the panel.
- B. Coordinate location of ceiling diffusers and registers with Architect's reflected ceiling plan.

END OF SECTION